



Inspection Checklist and Notice of Violation

Section A: General

- A-1:** An inspection, test, and maintenance log for the fire alarm system has not been maintained.
- A-2:** An inspection, test, and maintenance log for smoke detectors has not been maintained.
- A-3:** An inspection, test, and maintenance log for the fire sprinkler system has not been maintained.
- A-4:** An inspection, test, and maintenance log for the standpipe system has not been maintained.
- A-5:** An inspection, test, and maintenance log for the fire pump has not been maintained.
- A-6:** An inspection, test, and maintenance log for the fire hydrants has not been maintained.
- A-7:** An inspection, test, and maintenance log for fire suppression systems has not been maintained.
- A-8:** An inspection, test, and maintenance log for the fire extinguishers has not been maintained.
- A-9:** An inspection, test, and maintenance log for exit and emergency illumination has not been maintained.
- A-10:** An inspection, test, and maintenance log for fire doors, dampers, and shutters has not been maintained.
- A-11:** An inspection, test, and maintenance log for stair pressurization systems has not been maintained.
- A-12:** An inspection, test, and maintenance log for the emergency generator has not been maintained.
- A-13:** An inspection, test, and maintenance log for smoke evacuation and containment systems not maintained.
- A-14:** Documentation showing that fire exit drills are regularly conducted has not been maintained.
- A-15:** Documentation that fire fighter service elevators are operated monthly has not been maintained.
- A-16:** Documentation that hotel emergency organization drills are performed has not been maintained.
- A-17:** Written emergency instructions meeting the life safety code for residents or guests not provided.
- A-18:** Other inspection, test, and maintenance log listed within the remarks section has not been maintained. (See Remarks)

Remarks (Indicate specific item number cited.)
.....
.....
.....
..... (Continue on reverse, if required.)

Section B: Means of Egress

- B-1:** The means of egress has been obstructed
- B-2:** Exit doors are locked when the building is occupied.
- B-3:** Door locks or latches do not meet NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-4:** Delayed egress locks do not meet all NFPA 101, *Life Safety Code*[®], 2009 Edition criteria.
- B-5:** Access control locks do not meet all NFPA 101, *Life Safety Code*[®], 2009 Edition criteria.
- B-6:** Electromagnetic hold open devices not maintained or provided.
- B-7:** Required panic hardware not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-8:** Fire exit hardware not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-9:** Exits not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-10:** Exit signs and exit directional signs not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-11:** Exit illumination not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-12:** Emergency lights not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-13:** Exit corridors not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-14:** Interior finish within the means of egress does not meet NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-15:** Stairs handrails and guardrails not provided or maintained per NFPA 101, *Life Safety Code*[®], 2009 Edition.
- B-16:** Exit discharge not provided or maintained to a public way.
- B-17:** Open flames or flame producing devices located in means of egress.
- B-18:** Other violations listed within the remarks section. (See Remarks)

Remarks (*Indicate specific item number cited.*)

.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....

(Continue on reverse, if required.)

Section D: Smoke and Heat Detectors

- D-1:** Smoke detectors not inspected, tested, and maintained per NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition.
- D-2:** Smoke detectors in need of sensitivity testing.
- D-3:** Smoke detectors need to be relocated to meet NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition.
- D-4:** Required smoke detectors are missing.
- D-5:** Heat detectors not inspected, tested, and maintained per NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition.
- D-6:** Heat detectors need to be relocated to meet NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition.
- D-7:** Required heat detectors are missing.
- D-8:** Other violations listed within the remarks section. (See Remarks)

Remarks (*Indicate specific item number cited.*)

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

..... (*Continue on reverse, if required.*)

Section E: Automatic Sprinkler Systems

- E-1: Hydraulic calculation or pipe schedule data plate missing or not provided.
- E-2: Sprinkler system needs inspection, testing, and maintenance per NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2008 Edition.
- E-3: Sprinkler system riser inspection tag missing or is not current.
- E-4: Sign indicating location of fire department connection missing.
- E-5: Access to fire department connection is obstructed.
- E-6: Fire Department connection caps missing or not provided.
- E-7: Labels for sprinkler system valves missing or labels are not provided.
- E-8: Post indicator and backflow preventer valves are missing locks and chains.
- E-9: Post indicator valves are not provided with signs identifying systems, buildings, or areas controlled.
- E-10: No spare head cabinet containing sufficient sprinkler heads and wrenches has been provided.
- E-11: Automatic sprinkler coverage is missing or inadequate.
- E-12: Sprinkler system coverage obstructed.
- E-13: Remote station monitoring by a UL® listed central station facility has not been provided.
- E-14: Other violations listed within the remarks section. (See Remarks)

Remarks (Indicate specific item number cited.)
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
..... (Continue on reverse, if required.)

Section F: Standpipe Systems

- F-1:** Standpipe system riser missing inspection tag or is not current.
- F-2:** Standpipe system in need of inspection, testing, and maintenance per NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2008 Edition.
- F-3:** Warning labels denoting pressures exceed 100 PSI not provided at fire hose valves.
- F-4:** Hose valve caps are missing from hose valve outlets.
- F-5:** Access to standpipe risers, fire hose cabinets, or fire hose valves is obstructed.
- F-6:** Fire hose needs inspection, testing, and maintenance per NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2008 Edition.
- F-7:** Pressure reducing valves need inspection, testing, and maintenance per NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2008 Edition.
- F-8:** Standpipe system pressure gauge is missing or is not working.
- F-9:** Hose valve cabinet or hose valve rack is damaged.
- F-10:** Other violations listed within the remarks section. (See Remarks)

Remarks *(Indicate specific item number cited.)*

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

..... *(Continue on reverse, if required.)*

Section M: Structural

- M-1:** Numerical street address is not visible from the roadway.
- M-2:** Building, suite, or unit number has not been posted.
- M-3:** Occupant load signs in assembly/meeting rooms/restaurants/lounges not posted.
- M-4:** Required fire-rated separation not provided or maintained. (***Referral to Bldg. Dept.***)
- M-5:** Automatic closure devices for fire-rated doors missing or in need of repair.
- M-6:** Fire-rated doors are not provided or maintained.
- M-7:** Fire-rated doors are not maintained closed.
- M-8:** Required draft stopping not provided or maintained.
- M-9:** Vertical openings not enclosed per NFPA 101, *Life Safety Code*[®], 2009 Edition. (Stairs, shaft ways, chutes, etc.)
- M-10:** Trash and linen chute doors in need of repair.
- M-11:** Accumulated combustible waste materials not removed.
- M-12:** Structural integrity not maintained. (Damaged structural elements) (***Referral to Bldg. Dept.***)
- M-13:** Dryers not vented to the exterior. (***Referral to Bldg. Dept.***)
- M-14:** Fire dampers and shutter need repair.
- M-15:** Interior finishes do not meet NFPA 101, *Life Safety Code*[®], 2009 Edition.
- M-16:** Other violations listed within the remarks section. (See Remarks)

Remarks (*Indicate specific item number cited.*)
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
..... (Continue on reverse, if required.)

